

81053

State of Oregon  
DEPARTMENT OF ENVIRONMENTAL QUALITY

Vol. 80 Page 3540

**CERTIFICATE  
OF FAVORABLE SITE EVALUATION FOR  
INDIVIDUAL SUBSURFACE SEWAGE DISPOSAL SYSTEM**  
(Not a permit for construction)

This is to certify that the following described property

Township 38S, Range 11E, Section 18; Tax Lot 2004;  
20 Acres, Bonanza Ridge

has been evaluated on 10-25-79 and found to be approvable for the installation of one subsurface sewage disposal system in accordance with ORS 454.605 through 454.755 and administrative rules of the Environmental Quality Commission promulgated thereunder.

This approval is given on the basis that the lot or parcel described above will not be further partitioned or subdivided and that conditions on subject or adjacent properties have not been altered in any manner which would prohibit issuance of a permit under the statutes and rules noted above. Any such subdivision, partitioning or alteration voids this certificate.

The subsurface sewage disposal system is to be located on the above-described property as follows:

1. A construction permit must be obtained from this office before this system is installed.
2. Test holes examined on 10-24-79 revealed a sandy loam soil.
3. A restrictive layer is between 24 and 36 inches from the ground surface.
4. Minimum drainfield and replacement area setbacks are 100 feet from all wells, and 10 feet from property lines.
5. An equal sized area for drainfield replacement must be reserved on the property and be kept free from development.
6. Drainfield trenches are not to exceed 24 inches in depth because of the restrictive layer.
7. This drainfield must be a serial distribution system.
8. 300 lineal feet of drainfield line are required.
9. A 1000 gallon septic tank should be used for this system.
10. Persons other than the property owner must be licensed to install the system.
11. Please provide your installer with a copy of this letter.
12. You must call this office to inspect the system before covering.

A system to be located anywhere on the lot or parcel other than as described above will require an additional site evaluation along with an additional fee.

This certification is valid until a subsurface sewage disposal system is installed pursuant to a permit obtained from Klamath Falls Branch or until earlier cancellation, pursuant to Commission rules, with written notice thereof by the Department of Environmental Quality to the then owners according to Department records or the county tax records, whichever are more current. Subject to the foregoing, this certification runs with the land and will automatically benefit subsequent owners of the land.

Issued: 10-25-79

Date

To: Robert Damuth

Landowner

5816 Independence 4306 FARGO

Address

Klamath Falls, OR 97601

City

State

Zip

By

*Ron Smith*

DEQ or Contract Agent

Ron Smith, R.S.  
Sanitarian

STATE OF OREGON; COUNTY OF KLAMATH; ss.

I hereby certify that the within instrument was received and filed for record on the 22nd day of February A.D., 19 80 at 11:39 o'clock A M., and duly recorded in Vol. M80 of Deeds on Page 3540.

FEE \$3.50

WM. D. MILNE, County Clerk

By Bernetha Helach Deputy

SP\*38460-340

80 FEB 22 AM 11 39

col